

ANNE ARUNDEL COUNTY

(3) THE FREE CHLORINE RESIDUAL OF THE POOL SHALL BE MAINTAINED BETWEEN 0.3 AND 1.0 PPM. DISINFECTANTS OTHER THAN CHLORINE (SUCH AS THAT USED IN THE HYLAC PROCESS) SHALL BE SUBJECT TO REVIEW OF THE APPROVING AUTHORITY.

(4) THE DELIVERY OF FILTERED WATER SHALL NOT BE INTERRUPTED FOR MORE THAN ONE (1) HOUR IN ANY ONE (1) CONTINUOUS TWENTY-FOUR (24) HOUR PERIOD (EXCLUDING THE TIME REQUIRED FOR THE BACKWASHING OPERATION, CLEANING THE HAIR AND LINT TRAP AND CLEANING OF THE CHLORINATOR).

(5) THE BATH HOUSE SHALL BE FREE OF HEALTH OR SAFETY HAZARDS.

(6) THE AUTOMATIC DISINFECTANT FEEDER SHALL NOT BE INOPERATIVE IN EXCESS OF TWENTY-FOUR (24) CONSECUTIVE HOURS.

(7) THE PH LEVEL OF THE POOL SHALL BE MAINTAINED BETWEEN 7.2 AND 7.6.

(8) NO CONDITIONS WHICH CONSTITUTE OR ARE CONDUCTIVE TO A HEALTH OR SAFETY HAZARD SHALL BE PERMITTED.

(9) THE POOL SHALL ONLY BE OPERATED UNDER THE ACTIVE SUPERVISION AND OBSERVATION OF THE NUMBER OF LIFEGUARDS SPECIFIED IN THE BELOW LISTED TABLE:

NUMBER OF PERSONS IN WATER	NUMBER OF LIFEGUARDS
1 - 30	1
31 - 100	2
101 - 250	3
FOR EACH ADDITIONAL 200 PERSONS	1 ADDITIONAL LIFEGUARD

SECTION 12-2103

(A) UPON WRITTEN APPROVAL OF THE APPROVING AUTHORITY, THE DEPARTMENT OF INSPECTIONS AND PERMITS SHALL ISSUE AN OPERATOR'S LICENSE TO ANY APPLICANT WHO IS NOT LESS THAN SIXTEEN (16) YEARS OF AGE, WHO HAS PAID AN APPLICATION FEE OF FIVE DOLLARS (\$5.00) AND WHO FULFILLS ANY ONE (1) OF THE BELOW LISTED