

## ANNE ARUNDEL COUNTY

A SINGLE GROUP OF FIXTURES MAY BE INSTALLED WITH THE DRAIN FROM A BACK-VENTED LAVATORY SERVING AS A WET VENT FOR A BATHTUB OR SHOWER STALL AND FOR THE WATER CLOSET, PROVIDED THAT:

(A) NOT MORE THAN ONE (1) FIXTURE UNIT IS DRAINED INTO A ONE AND ONE-HALF INCH (1 1/2") DIAMETER WET VENT OR NOT MORE THAN FOUR (4) FIXTURE UNITS DRAIN INTO A TWO INCH (2") DIAMETER WET VENT.

(B) THE HORIZONTAL BRANCH SHALL BE A MINIMUM OF TWO INCHES (2") AND CONNECT TO THE STACK AT THE SAME LEVEL AS THE WATER-CLOSET DRAIN OR BELOW THE WATER CLOSET DRAIN WHEN INSTALLED ON THE TOP FLOOR. SAID BRANCH MAY ALSO CONNECT TO THE WATER-CLOSET BEND."

## (21) "SECTION 1206 STACK VENTING

## 1206.1 FIXTURE GROUPS

A SINGLE BATHROOM GROUP OF FIXTURES CONSISTING OF A WATER CLOSET, BASIN, SHOWER OR TUB AND A KITCHEN SINK (WITH DISPOSAL AND DISHWASHER) LOCATED BACK-TO-BACK TO THE BATHROOM, OR TWO (2) BATHROOMS BACK-TO-BACK, EACH CONSISTING OF ONE (1) TOILET, BASIN, SHOWER OR TUB MAY BE INSTALLED WITHOUT INDIVIDUAL FIXTURE VENTS IN A ONE-STORY BUILDING OR ON THE TOP FLOOR OF A BUILDING PROVIDED EACH FIXTURE DRAIN CONNECTS INDEPENDENTLY TO THE STACK AND IN ACCORDANCE WITH THE REQUIREMENTS IN TABLE 1211.1. A SIDE-INLET CONNECTION INTO A FULL FOUR INCH (4") CLOSET BEND SHALL BE CONSIDERED TO BE AN INDEPENDENT CONNECTION TO THE STACK.

## 1206.2 LOWER FLOORS

LOWER FLOORS MAY BE VENTED AS SET FORTH IN PARAGRAPH 1206.1, PROVIDED THAT (I) A SEPARATE WYE AND UPRIGHT ONE-EIGHTH (1/8) BEND IS INSTALLED IN THE STACK, (II) THE STACK GROUP IS INSTALLED ABOVE THE ONE-EIGHTH (1/8) BEND, AND (III) A TWO INCH (2") VENT IS INSTALLED NOT LESS THAN SIX INCHES (6") ABOVE THE FLOOD LINE OF THE TOP FIXTURE."

## (22) "SECTION 1207.4 LOOP VENTS

A FIXTURE OTHER THAN A KITCHEN SINK OR DISPOSAL HAVING A HYDRAULIC LOAD OF NOT MORE THAN TWO (2) FIXTURE UNITS MAY BE CONNECTED TO A TWO INCH