

## ANNE ARUNDEL COUNTY

A CLEANOUT SHALL BE PLACED IN THE BUILDING SEWER AND BUILDING STORM SEWER AT THE PROPERTY LINE AND BROUGHT TO SURFACE ON A FORTY-FIVE DEGREE (45°) ANGLE OR MAY BE BROUGHT UP TO THE SURFACE WITH A Y AND 1/8 BEND. THE CLEANOUT MUST EXTEND FOUR INCHES (4") ABOVE FINISHED GRADE OR BE ACCESSIBLE. THE EXTENSION TO GRADE SHALL BE NOT LESS THAN SERVICE WEIGHT BELL AND SPIGOT CAST IRON. THE ONLY FITTING ALLOWED BETWEEN THE Y OR Y AND 1/8 BEND AND THE CONNECTION SHALL BE THE PROPER REDUCER.

**(16) SECTION 600.4.1.1 WHERE REQUIRED**

(A) WHENEVER A FLOOR DRAIN DISCHARGES THROUGH AN OIL INTERCEPTOR, IT MUST FIRST DISCHARGE THROUGH A SAND INTERCEPTOR. MULTIPLE FLOOR DRAINS MAY DISCHARGE INTO ONE (1) SAND INTERCEPTOR WITHOUT INDIVIDUAL FLOOR TRAPS.

(B) WHENEVER THE DISCHARGE OF A FLOOR DRAIN MAY CONTAIN SOLIDS OR SEMISOLIDS THAT WOULD BE HARMFUL TO A DRAINAGE SYSTEM, OR TEND TO CHOKO THE SYSTEM, THE DISCHARGE MUST BE THROUGH A SAND INTERCEPTOR.

(C) INTERCEPTORS SHALL ALSO BE REQUIRED WHEN THE ADMINISTRATIVE AUTHORITY DEEMS THEM ADVISABLE TO PROTECT THE DRAINAGE SYSTEM.

**(17) SECTION 708.4 SHOWER FLOORS OR RECEPTORS**

FLOORS OR RECEPTORS UNDER SHOWER COMPARTMENTS SHALL BE LAID ON OR BE SUPPORTED BY A SMOOTH AND STRUCTURALLY SOUND BASE. FLOORS UNDER SHOWER COMPARTMENTS, OTHER THAN THOSE LAID DIRECTLY ON THE GROUND SURFACE OR WHERE PREFABRICATED RECEPTORS HAVE BEEN PROVIDED, SHALL BE LINED AND MADE WATERTIGHT BY THE PROVISION OF SUITABLE SHOWER PANS OF DURABLE MATERIAL. SUCH PANS SHALL TURN UP ON ALL SIDES AT LEAST TWO INCHES (2") ABOVE THE FINISHED THRESHOLD LEVEL. PANS SHALL BE SECURELY FASTENED TO THE WASTE OUTLET AT THE SEEPAGE ENTRANCE MAKING A WATERTIGHT JOINT BETWEEN THE PAN AND THE OUTLET. FLOOR SURFACES SHALL BE CONSTRUCTED OF SMOOTH, NON-CORROSIVE, NON-ABSORBENT, AND WATERPROOF MATERIALS.

**(18) SECTION 717 FLOOR DRAINS****717.1 TRAPS AND STRAINERS**

FLOOR DRAINS SHALL HAVE A MINIMUM WATER SEAL OF THREE INCHES (3") AND SHALL BE PROVIDED WITH REMOVABLE STRAINERS. THE OPEN AREA OF STRAINER SHALL BE AT LEAST TWO-THIRDS OF THE CROSS-SECTION AREA OF THE DRAIN LINE TO WHICH IT CONNECTS. FLOOR DRAIN TRAP SEALS SUBJECT TO EVAPORATION SHALL HAVE A WATER SEAL OF SIX INCHES (6") OR SHALL BE FED FROM AN APPROVED PLUMBING FIXTURE BY MEANS OF AN APPROVED AUTOMATIC PRIMING DEVICE OR BY ANY OTHER