

ANNE ARUNDEL COUNTY

APPLICATION. WHEN THERE IS EVIDENCE THAT A GEOGRAPHICAL FORMATION HAS A HIGH AND FLUCTUATING WATER TABLE DURING SPECIFIED MONTHS OF THE YEAR, THE APPROVING AUTHORITY MAY INDICATE THE TIMES DURING WHICH THE TESTS ARE TO BE MADE.

(35) SECTION 1600.2

(C) PERCOLATION TESTS SHALL BE CONSIDERED INVALID AFTER ONE (1) YEAR FROM THE DATE OF TESTING AND SHALL BE MADE IN SUFFICIENT NUMBER AND AT SUCH LOCATIONS AS SPECIFIED BY THE APPROVING AUTHORITY TO ASSURE A RELIABLE DETERMINATION OF SUBSURFACE CONDITIONS. THE PERCOLATION DRAWDOWN RATE MAY RANGE BETWEEN 0 AND 30 MINUTES. THE RESULTS OF PERCOLATION TESTS SHALL BE CONSIDERED IN CONJUNCTION WITH AVAILABLE INFORMATION ON TOPOGRAPHY, SOIL TYPE AND CONDITION, SURFACE AND SUBSURFACE DRAINAGE CONDITIONS, WATER TABLE LEVEL, AND THE HISTORY OF FAILURE OF SEPTIC SYSTEMS IN SURROUNDING AREAS, AND SOIL MAPS DATA.

(36) SECTION 1600.2

(D) (I) WHEN, UPON REVIEW OF THE APPLICATION, THE APPROVING AUTHORITY IS SATISFIED THAT THE PROPOSED DESIGN IS ADEQUATE, A WRITTEN PERMIT TO PROCEED WITH CONSTRUCTION SHALL BE ISSUED. THE LENGTH OF TIME A PERMIT IS TO RUN SHALL BE SPECIFIED IN SUCH PERMIT AND SHALL NOT EXCEED ONE (1) YEAR. SAID PERMIT SHALL AUTOMATICALLY BECOME INOPERATIVE AT THE EXPIRATION OF THE PRESCRIBED PERIOD.

(II) WHEN, UPON REVIEW OF THE APPLICATION, THE APPROVING AUTHORITY IS CONVINCED THAT THE PROPOSED DESIGN IS INADEQUATE, OR SOIL AND GEOLOGICAL CONDITIONS ARE SUCH AS TO PRECLUDE SAFE AND PROPER OPERATIONS OF THE DESIRED INSTALLATION(S), A PERMIT TO PROCEED WITH CONSTRUCTION SHALL BE DENIED.

(37) SECTION 1600.3.1 DESIGN

THE DESIGN OF THE INDIVIDUAL SEWAGE DISPOSAL SYSTEM MUST TAKE INTO CONSIDERATION LOCATION WITH RESPECT TO WELLS OR OTHER SOURCES OF WATER SUPPLY, TOPOGRAPHY, WATER TABLE, SOIL CHARACTERISTICS, AREA AVAILABLE, AND MAXIMUM OCCUPANCY OF THE BUILDING AND FACILITIES REQUIRING WATER USAGE.

(38) SECTION 1600.3.3 SANITARY SEWAGE

THE SYSTEM SHALL BE DESIGNED TO RECEIVE ALL SANITARY SEWAGE, INCLUDING LAUNDRY WASTE FROM THE BUILDING, AND BACKWASH EFFLUENT FROM SWIMMING POOL WHEN APPROPRIATE. DRAINAGE FROM BASEMENT FLOOR, FOOTING OR ROOFS SHALL NOT ENTER THE SYSTEM.